



WINNEBAGO COUNTY

— ILLINOIS —

County Administration Building
404 Elm Street
Rockford, Illinois 61101

Purchasing Department
Phone: 815-319-4380
Fax: 815-319-4381

July 30, 2025

ADDENDUM ONE

1st FLOOR LED LIGHTS UPGRADES FOR WINNEBAGO COUNTY JUVENILE JUSTICE CENTER INVITATION FOR BID #25B-2423

All bid requirements and information have can be found at [Open Bids, Quotes & RFPs](#)

As a reminder see below for Bid Submittal Checklist

✓	BID SUBMITTAL CHECKLIST
1.	Submit one (1) Original signed Bid, plus one (1) copy
2.	Bid Pricing & Schedule
3.	Bid Form
4.	<i>Responsible Bidder for Public Works Projects – Provide appropriate certificate</i>
5.	Business References Form
6.	Bidder's Subcontractor Form
7.	Bid Exception Form
8.	Use of the <u>Bid Return Label</u>

1. Are any of the new flat panel LED fixtures required to include emergency or battery backup lighting? **No**

2. Do any of the new flat panels need to meet a specific DLC (Design Lights Consortium) requirement? **No**

3. Should our RFP submission reflect potential ComEd rebate amounts? **Submit rebate and final cost after rebate has been applied.**

4. For the suspended 1x4 fixtures, are we required to specify a new LED fixture as a direct replacement? **Yes**

5. In addition to Questions above to calculate ComEd rebates, we need to know the existing wattage of the current fixtures (e.g., quantities of 4-lamp T8 2x4 vs. 3-lamp T8 2x4s etc.).
We are replacing a total of 774 F32 T8 lamps for this project.

6. There is a section for labor, installation, and materials. I haven't seen that one before on your forms, but the installation price would be the labor. Or is there something specific you are looking for? Labor (man hour) costs need to be submitted. Installation costs will be costs that associated with the install of materials, not hourly labor costs. Examples would be if lifts, scaffolding or anything that is charged to aid in the installation of the materials. Material cost is just that, materials for the projects that will be installed and left on site.







