

BASEMENT REPAIRS WINNEBAGO COUNTY COURTHOUSE
400 WEST STATE STREET ROCKFORD, ILLINOIS

LARSON & DARBY GROUP

4949 Harrison Avenue, Suite 100
815/484-0739

ARCHITECTURE-ENGINEERING-INTERIORS

Rockford, IL 61108
FAX 815.229.9867

TO: ALL BIDDERS

RE: ADDENDUM #2

Changes to Bidding Documents Dated: Issued for Bidding January 22, 2024

PROJECT: BASEMENT REPAIRS
WINNEBAGO COUNTY COURTHOUSE
400 WEST STATE STREET, ROCKFORD, ILLINOIS 61101

WINNEBAGO COUNTY BID # 24B-2334

LDG PROJECT 32315


DATE: February 26, 2024

Please attach this Addendum to the Project Manual and Drawings for the referenced project. Take the changes to the Project Manual and Drawings into consideration in preparing your Bid.

Bidders shall make note in writing on Bid Form that this Addendum has been taken into consideration. Failure to do so may be sufficient cause to reject the Bid.

LARSON & DARBY GROUP

By


Ged Trias, AIA

This Addendum consists of 2 pages.

BID DUE DATE ADJUSTMENT:

The bid due date has been adjusted to:

Tuesday, March 5th 2024 at 2:30 PM

I. CLARIFICATIONS

- A. The existing glazed block surfaces in the areas of renovation do not need to be painted only the new or unpainted block surfaces.
- B. The county is not accepting individual subcontractor bids for this project. The County's expectation is that bids will be received from general contractors capable of executing the entire project scope of work.
- C. Electrical Drawing Clarifications:
 - 1. What size is the ductwork to and from the louvers supposed to be? **8" round**

BASEMENT REPAIRS WINNEBAGO COUNTY COURTHOUSE
400 WEST STATE STREET ROCKFORD, ILLINOIS

2. What size are the outside wall Brick Vent to be? **The drawing calls for model # BVE157.**
3. Does the Brick Vent need a motorized control damper? **No.**

END OF ADDENDUM #1