



WINNEBAGO COUNTY

— ILLINOIS —

County Administration Building
404 Elm Street
Rockford, Illinois 61101

Purchasing Department
Phone: 815-319-4380
Fax: 815-319-4381

May 30, 2024

ADDENDUM TWO

ROOF REPLACEMENT (LOWER LEVEL) AT JUVENILE JUSTICE CENTER REQUEST FOR BID #24B-2346

1. Can someone confirm if it's sloped with insulation (and if so – what's the pitch?) or if it's sloped structurally? The Juvenile Justice Center has a slope of $\frac{1}{4}$ 12. We cannot completely determine if the pitch is structure or insulation, but from what we can see it appears that the slope to the Juvenile Justice Center roof is structural.
2. Does the new insulation need to be R30? As far as insulation is concerned, we are not bringing the entire roof up to R30, we are only having damaged or wet areas repaired while it is exposed.

END OF ADDENDUM TWO
