



WINNEBAGO COUNTY

— ILLINOIS —

County Administration Building
404 Elm Street
Rockford, Illinois 61101

Purchasing Department
Phone: 815-319-4380
Fax: 815-319-4381

May 30, 2024

ADDENDUM ONE

ROOF REPLACEMENT AT ADULT PROBATION INVITATION FOR BID #24B-2348

1. Can someone confirm if it's sloped with insulation (and if so – what's the pitch?) or if it's sloped structurally? **The Adult Probation roof does not have a slope.**
2. Does the new insulation need to be R30? **As far as insulation is concerned, we are not bringing the entire roof up to R30, we are only having damaged or wet areas repaired while it is exposed.**
3. It is the county's intent to do this project in the fall of 2024, start date no later than October 1. **We are also flexible to the contractor's availability and scheduling.**

END OF ADDENDUM ONE
