



WINNEBAGO COUNTY

— ILLINOIS —

County Administration Building
404 Elm Street
Rockford, Illinois 61101

Melinda Macias
Purchasing Specialist
Phone: 815-319-4380
Fax: 815-319-4381

August 18, 2025

ADDENDUM ONE

ADULT PROBATION- 3RD FLOOR AIR HANDLER REPLACEMENT INVITATION FOR BID #25B-2429

Bidders are required to indicate on their Proposer Signature Form that they have received and acknowledged Addendum One. Below are questions that were submitted, followed by the answer;

1. The return blower is only 3 years old, is this included in the project? **No, do not replace return blower.**
2. Please confirm that the existing hot water control valve shall be replaced with the replacement of the 3rd floor air handling unit? **Yes**

Any questions should be directed to the Purchasing Department, 404 Elm Street, Room 202, Rockford, IL 61101 or by phone 815-319-4380, or email purchasing@purchasing.wincoil.gov

END OF ADDENDUM ONE