



WINNEBAGO COUNTY

— ILLINOIS —

County Administration Building
404 Elm Street
Rockford, Illinois 61101

Purchasing Department
Phone: 815-319-4380
Fax: 815-319-4381

February 19, 2025

ADDENDUM ONE

NURSE CALL SYSTEM SOLUTION AT RIVER BLUFF NURSING HOME REQUEST FOR PROPOSAL #25P-2384

1. Would like to know how you would like the proposal to split up since it will go over a couple of years.
Please see below for phased pricing regarding your submission.

Nurse Call System Solution	
Phase One	Price
Initial System Set-Up	
Cabling Ran to Neighborhoods From IDFs	
Blue Jay (Demo & Installation)	
Eagle (Demo & Installation)	
Total Phase One:	
Phase Two	
Dove (Demo & Installation)	
Cardinal (Demo & Installation)	
Total Phase Two:	
Annual Maintenance Fees (software, support, licenses) if applicable	

2. Please confirm that the Isolation Rooms (141/144, 241/244, 341/344, 441/444) are 1-bed occupancy.
Yes
3. Do the Isolation Rooms in each section (141/144, 241/244, 341/344, 441/444) have a shared toilet, or private toilet?
Private
4. Should the new call cord station in each resident room (by the bed) be mounted within ADA height guidelines (42" - 48")? **Yes**
5. Are there any common area stations that should have an emergency staff button or pull cord station (Dining, Therapy, Therapy Toilet, Lounges, etc.)? **Yes (how many at each location/wing)**
Main Dining Room Restrooms 2
Therapy Restrooms 2
Rec Room Restrooms 2
Not needed on neighborhood Dining Room or Lounges
6. Are there any additional door alarms that will be tied into the nurse call system (courtyard doors, gates, etc.)? **Yes**
Gates: 4
Courtyard Doors: 4 B/C, 2 D/E
Exit Doors on Neighborhoods: 3 on each = total of 12
7. Is plenum-rated cable required to be ran in the facility for the new nurse call system?
Yes
8. If it is necessary to install surface-mount raceway from the new nurse call device to the acoustical ceiling, should it be metallic, or plastic?
Metal
9. Does a corridor light on the old DuKane nurse call system illuminate when a sleeping room smoke detector is in alarm condition?
No
10. Should each vendor disclose the total dollar amount for any applicable software maintenance fees that would apply to the new nurse call system for a 5-year period? **Yes, please include annual maintenance fees associated with a new nurse call system. Keeping in mind, the requested pricing structure and the initial annual fees being less while we split the project into phases.**
11. If its worth using any of the existing systems, please provide solutions in your submission.
12. Please keep in mind while scheduling work we will coordinate shifting the residents as much as possible, however when it comes to the Dove unit, we will have some special circumstances as this is the dementia unit.

END OF ADDENDUM ONE
