



COUNTY OF WINNEBAGO

REGIONAL PLANNING & ECONOMIC DEVELOPMENT DEPARTMENT

County Administration Building
404 Elm St. - Room 403
Rockford, Illinois 61101

**BUILDING
PLANNING & ZONING**

Phone: (815) 319-4350
Fax: (815) 319-4351
www.co.winnebago.il.us

CUTTING, NOTCHING AND DRILLING **IRC 2003 Section R502.8**

For SI: 1 inch = 25.4 mm

R502.8 Drilling and notching.

Structural floor members shall not be cut, bored or notched in excess of the limitations specified in this section. See Figure R502.8.

R 502.8.1 Sawn lumber.

Notches in solid lumber joists, rafters and beams shall not exceed one-sixth of the depth of the member, shall not be longer than one-third of the depth of the member and shall not be located in the middle one-third of the span. Notches at the ends of the member shall not exceed one-fourth the depth of the member. The tension side of members 4 inches (102 mm) or greater in nominal thickness shall not be notched except at the ends of the members. The diameter of holes bored or cut into members shall not exceed one-third the depth of the member. Holes shall not be closer than 2 inches (51 mm) to the top or bottom of the member, or to any other hole located in the member. Where the member is also notched, the hole shall not be closer than 2 inches (51 mm) to the notch.

R502.8.2 Engineered wood products.

Cuts, notches and holes bored in trusses, laminated veneer lumber, glue-laminated members or I-joists are not permitted unless the effects of such penetrations are specifically considered in the design of the member.

Revised 11-06 (JM)

~ It is our mission to provide high quality services and promote a safe community for all people in Winnebago County ~