

FOREST PRESERVES OF WINNEBAGO COUNTY

MACKTOWN GOLF CLUBHOUSE WATER MAIN CONNECTION

BID FP# 23B-2270

ADDENDUM # 3

1) What size is the existing water main?

The water main size is 2"

2) For the well abandonment, does the well need to be removed or just abandoned in place?

The existing well needs to be abandoned as per local/County code > (removed below surface of ground and filled with bentonite)> will likely have to subcontract with local certified well contractor.

3) Does the well pressure tank require to be removed from the basement?

The well tanks need to be removed from the basement and disposed of.

4) What material is the existing water main?

Existing water main material coming into the building is galvanized and thought to be the same material extending to the well.