

FOREST PRESERVES OF WINNEBAGO COUNTY

MACKTOWN GOLF CLUBHOUSE WATER MAIN CONNECTION

BID FP# 23B-2270

ADDENDUM # 4

- 1.) **What are the dimensions of the existing well to be removed? This is important for quantity of materials needed.**

8" diameter Well

280 ft Deep

78 ft to Water

120 ft 1-1/4" Schedule 80 on pump

- 2.) **Who can I reach out to and ask a question about what specific type of backflow RPZ valve is required?**

I would have you contact the Village of Rockton and ask to speak with someone with their water department in order to answer this specific question.