



WINNEBAGO COUNTY

— ILLINOIS —

January 19, 2024

ADDENDUM TWO

CHILLER REBUILD AT CRIMINAL JUSTICE CENTER BID #23B-2325

This addendum is issued to modify, clarify, or correct the original Bid Solicitation and is hereby made part of the contract documents. **Acknowledgement of this addendum is required on the Bid Form (page 23 of #23B-2325 Solicitation Document).**

Questions presented at Mandatory Pre-Bid Meeting and Site Visit:

1. When was the last Eddie Curve Test? **2022**
2. What is the completion date/timeline? **Goal: Finish by June 1**
3. There are upgrades that can most economically be performed in conjunction with the overhaul.
 - A. Would the county consider a controls upgrade? **Not at this time**
 - B. Would the county consider a motor starter refresh? **Yes, see SCOPE OF WORK change below.**

ADDITION TO SCOPE OF WORK

1. Pre-test motor to ensure viability for rebuild prior to tear-down.
2. Test heat exchanger tubes for viability for rebuild prior to tear-down.
3. Motor starter refresh.

INFORMATION

1. All questions or requests for information are to be submitted in writing to purchasing@purchasing.wincoil.gov

END OF ADDENDUM TWO