



WINNEBAGO COUNTY

— ILLINOIS —

February 21, 2024

ADDENDUM ONE

ROOF REPLACEMENT AT JUVENILE JUSTICE CENTER BID #24B-2339

This addendum is issued to modify, clarify, or correct the original Bid Solicitation and is hereby made part of the contract documents. **Acknowledgement of this addendum is required on the Bid Form (page 24 of #24B-2339 Solicitation Document).**

REVISIONS

1. Please bid ½" HD ISO substrate board.
2. 60 mil membrane thickness.
3. Project will require a road closure, consider closure permit cost in the bid. Please see photo below of the crane location.

CLARIFICATIONS

1. Cost of permit, see page 13 of solicitation: **PERMITS, FEES, AND NOTICES.**

INFORMATION

1. To schedule additional site visits, contact County Facilities Department at 815-319-4670.
2. All questions or requests for information are to be submitted in writing to purchasing@purchasing.wincoil.gov



END OF ADDENDUM ONE