

Fire Alarm Equipment Summary by Building

Building / Location	Panel Type	Quant.	Fire Alarm Det.						Notification Devices			Batt's		Firefighters Phone	
			Smoke	Duct	Heat	Module	Pull	NAC	Horn	Speaker	Strobes	12v	12v	Set	Jack
			Det.	Det.	Det		Stations	Panels	Strobes	Strobes		7ah	100ah		
Juvenile Detention 5350 Northrock Dr	Notifier nfs-320	1	37	22	21	18	7	0	11	0	0		2-15AH	0	0
Courthouse 400 W. State St.	Notifier 3030	1	271	10	43	40	52	16	0	119	280	32	2	6	46
Old Courthouse 403 Elm St.	Notifier 640	1	47	8	1	9	8	1	0	42	26	2	2-55ah	5	8
Public Safety Bldg 420 W.State St.	Notifier 3030	1	367	19	50	25	41	8	0	78	141	16	2	6	44
Admin Bldg 404 Elm St.	Notifier 640	1	159	16	9	15	22	4	0	48	78	8	2-55ah	7	19
Juvenile Justice Cent 214 S. Court St.	Notifier 640	1	15	2	11	10	8	4	0	160	9	8	4	0	0
Animal Services 4517 N. Main St.	SFP-400B	1	14	2	3	2	3	0	10	0	0	2	2-12ah	0	0
River Bluff Nursing 4401 N. Main St.	Notifier 3030	1	323	18	144	32	41	6	85	0	39	12	2	0	0
Health Dept. 555 N. Court St.	Notifier 320	1	23	4	19	14	16	2	67	0	17	4	2-55ah	0	0

CJC Courts	Notifier3030	1	34	10	28	36	25	10	139	0	52	20	2	0	0
------------	--------------	---	----	----	----	----	----	----	-----	---	----	----	---	---	---

650 W. State St.

Note 1

9 *The 9 represents that 9 of the 34 smoke detectors are in the duct work*

CJC Corrections	Notifier 3030	1	513	29	222	67	50	17	0	278	108	34	6	12	40
-----------------	---------------	---	-----	----	-----	----	----	----	---	-----	-----	----	---	----	----

650 W. State St.

Note 2

279 *The 279 represents that 279 of the 513 smoke detectors are in the duct work*

Adult Probation Bldg	Simplex 4005		33	7	19	0	16	1	36	0	23	4	0	0	0
----------------------	--------------	--	----	---	----	---	----	---	----	---	----	---	---	---	---

526 W. State St.